

# bsi.



## Certificate of Constancy of Performance

This is to certify that:

**VIGITECH Midi Vision**  
16 Avenue de Gameville  
31650 Saint-Orens de Gameville  
France

Holds Certificate No:

**0086-CPR-611921**

In respect of:

**EN 14604:2005**

**Battery Powered Smoke Alarms**

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the above construction product.

This certificate attests that all the provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the above standard under system 1/1+ are applied and that the product fulfils all the prescribed requirements set out above.

For and on behalf of BSI,  
a Notified Body for the above Regulation  
(Notified Body Number 0086):

Gary Fenton, Global Assurance Director

This certificate remains valid as long as the test methods and/or factory production control requirements included in the harmonised standard(s), used to assess the performance of the declared characteristics, do not change and the product(s), and the manufacturing conditions in the plant(s) are not modified significantly.

First Issued: 05 March 2014

Latest Issue: 05 March 2014

Page 1 of 4

...making excellence a habit.™

# bsi.



## Certificate of Constancy of Performance

No. **0086-CPR-611921**

Manufacturer Importer

**VIGITECH Midi Vision**  
16 Avenue de Gameville  
31650 Saint-Orens de Gameville  
France

### Product Information

MANUFACTURER IMPORTER

**Model Reference**

VIGITECH

**Type**

Battery Powered Photoelectric Smoke Alarm.

First Issued: 05 March 2014

Latest Issue: 05 March 2014

Page 2 of 4

...making excellence a habit.™



# Certificate of Constancy of Performance

No. **0086-CPR-611921**

## Appendix 1

Harmonised Technical Specification		EN 14604:2005
Essential Characteristics	Performance	Clause
<b>Nominal activation conditions / sensitivity / response delay (response time) and performance under fire conditions</b>		
Smoke alarm signals	Pass	4.12
Repeatability	Pass	5.2
Directional dependence	Pass	5.3
Initial sensitivity	Pass	5.4
Air movement	Pass	5.5
Dazzling	Pass	5.6
Fire sensitivity	Pass	5.15
Sound output	Pass	5.17
Sounder durability	Pass	5.18
<b>Operational Reliability</b>		
Compliance	Pass	4.1
Individual alarm indicator	Pass	4.2
Means of calibration	Pass	4.5
User replaceable components	Pass	4.6
Normal power source	Pass	4.7
Electrical safety requirements	Pass	4.9, 5.24
Routine test facility	Pass	4.10
Battery removal indication	Pass	4.13
Battery connections	Pass	4.14
Battery capacity	Pass	4.15
Protection against the ingress of foreign bodies	Pass	4.16
Marking and data	Pass	4.19
Impact	Pass	5.11
Battery fault warning	Pass	5.16
Battery reversal	Pass	5.22
<b>Tolerance to supply voltage</b>		
Variation in supply voltage	Pass	5.21

First Issued: 05 March 2014

Latest Issue: 05 March 2014

...making excellence a habit.™

BSI 05/14/14



# Certificate of Constancy of Performance

No. **0086-CPR-611921**

## Appendix 1 (continued)

Harmonised Technical Specification	EN 14604:2005	
Essential Characteristics	Performance	Clause
<b>Durability of Operational Reliability</b>		
Dry heat	Pass	5.7
Cold (operational)	Pass	5.8
Damp heat (operational)	Pass	5.9
Sulphur dioxide (SO <sub>2</sub> ) corrosion	Pass	5.10
Vibration (operational)	Pass	5.12
Vibration (endurance)	Pass	5.13
<b>Durability of Operational Reliability, Electrical Stability</b>		
Electromagnetic compatibility (EMC), immunity (operational)	Pass	5.14